DECLARATION OF PERFORMANCE

in accordance with Construction Products Regulation 2011 as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020

PASSIVE FIRE STOP SYSTEMS

ASTRO INTU®

MASTIC (PENETRATION)

0843-CPR-1385

1. Unique identification code of product-type:

INTUM

2. Intended use/es:

For fire compartmentation and / or fire protection or performance, 0843-UKTA-24/0037 and EAD 350454-00-1104.

3. Manufacturer:

Astroflame Fireseals Ltd, Unit 8, The I O Centre, Stephenson Road, Segensworth, Fareham Hampshire, PO15 5RU

4. Not applicable

5. System/s of AVCP: AVCP - System 1

6b. European Assessment Document: EAD 350454-00-1104 - September 2017

UK Technical Assessment: 0843-UKTA-24/0037 Technical Assessment Body: UL International (UK) Ltd

Notified Body/ies: 0843

7. Declared performance:

E	
Essential Characteristics	Performance/Harmonised technical specification
Reaction to Fire	Class F according to EN13501-1
Reaction to Fire	Resistance to fire performance & field of application in accordance with EN13501-2 See 0843-UKTA-24/0037 Annex A
Air Permeability	Tested in accordance with EN 1026, See 0843-UKTA-24/0037 Annex B
Dangerous Substances	See 0843-UKTA-24/0037 Section 3
Airborne Sound Insulation	Tested in accordance with EN ISO 10140-2:2010 & EN ISO 140-3 & EN ISO 717-1 See 0843-UKTA-24/0037 Section 3 - Rw (C;Ctr) = 63 (G;-2) dB & Rw (C;Ctr) 38dB
Service & Durability	Type X intended for use at conditions exposed to weathering -20°C to +70°C in accordance with EOTA technical documents TR024
Movement Capability	EAD 350454-00-1104, clause 2.2.13, 0843-UKTA-24/0037
Other	Not applicable/No performance determined

8. Appropriate Technical Documentation and/or Specific Technical Documentation: 0843-UKTA-24/0037 Link to the online copy of the declaration of performance: www.astroflame.com

Signed on the behalf of the manufacturer by:

P.Kieser - Managing Director 16/10/2024

(Place of signature : Segensworth Fareham)

C.Dickens - Technical Managing 16/10/2024

Mahn

Astroflame (Fireseals) LTD: Unit 8, I.O Centre: Stephenson Road: Segensworth: Fareham: PO15 5RU

T - 01329 844500 : W - www.astroflame.com : E - sales@astroflame.com