in accordance with Construction Products Regulation 2011 as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020

ASTRO[®]

PS COATING

0843-CPR-1393



PSC

2. Intended use/es:

For fire compartmentation and / or fire protection or performance, 0843-UKTA-24/0046 and EAD 350454-00-1104.

3. Manufacturer:

Astroflame Fireseals Ltd, Unit 8, The I O Centre, Stephenson Road, Segensworth, Fareham Hampshire, PO15 5RU

- 4. Not applicable
- 5. System/s of AVCP: AVCP System 1
- 6b. European Assessment Document: EAD 350454-00-1104 September 2017 UK Technical Assessment: 0843-UKTA-24/0046
 Technical Assessment Body: UL International (UK) Ltd Notified Body/ies: 0843

7. Declared performance:

Essential Characteristics	Performance/Harmonised technical specification
Reaction to Fire	Class F according to EN13501-1
Resistance to Fire	Resistance to fire performance & field of application in accordance with EN13051-2 See 0843-UKTA-24/0046 Annex A
Air Permeability	Tested in accordance with EN 1026, See 0843-UKTA-24/0046 Annex B
Dangerous Substances	0843-UKTA-24/0046 Section 3
Service & Durability	Z1 (0/+40c) intended for use at internal conditions with high humidity (85%) in accordance with EOTA technical documents TR024
Other	Not applicable/No performance determined

8. Appropriate Technical Documentation and/or Specific Technical Documentation: 0843-UKTA-24/0046 Link to the online copy of the declaration of performance: www.astroflame.com

Signed on the behalf of the manufacturer by:

P.Kieser - Managing Director 14/11/2024

(Place of signature : Segensworth Fareham)

Alichw

C.Dickens - Technical Managing 14/11/2024