

## DECLARATION OF PERFORMANCE

in accordance with Construction Products Regulation 2011 as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020

**ASTRO X SERIES®**

**CE PIPE WRAP**

**0843-CPR-1390**



**1. Unique identification code of product-type:**

XSPW

**2. Intended use/es:**

For fire compartmentation and / or fire protection or performance, 0843-UKTA-24/0042 and EAD 350454-00-1104.

**3. Manufacturer:**

Astroflame Fireseals Ltd, Unit 8, The I O Centre, Stephenson Road, Segensworth, Fareham Hampshire, PO15 5RU

**4. Not applicable**

**5. System/s of AVCP:** AVCP - System 1

**6b. European Assessment Document:** EAD 350454-00-1104 - September 2017

**UK Technical Assessment:** 0843-UKTA-24/0042

**Technical Assessment Body:** UL International (UK) Ltd

**Notified Body/ies:** 0843

**7. Declared performance:**

Essential Characteristics	Performance/Harmonised technical specification
Reaction to Fire	Class F according to EN13501-1
Resistance to Fire	Resistance to fire performance & field of application in accordance with EN13051-2 See 0843-UKTA-24/0042 Annex A
Dangerous Substances	0843-UKTA-24/0042 Section 3
Service & Durability	Type X intended for use at conditions exposed to weathering -20°C to +70°C in accordance with EOTA technical documents TR024
Other	Not applicable/No performance determined

**8. Appropriate Technical Documentation and/or Specific Technical Documentation:** 0843-UKTA-24/0042

Link to the online copy of the declaration of performance: [www.astroflame.com](http://www.astroflame.com)

Signed on the behalf of the manufacturer by:

P.Kieser - Managing Director 04/11/2024

(Place of signature : Segensworth Fareham)

C.Dickens - Technical Managing 04/11/2024