

# CERTIFICATE OF CONSTANCY OF PERFORMANCE

This is to certify that UL International (UK) Ltd. did undertake the relevant AVCP procedures for the equipment identified below which was found to be in compliance with the Construction Products Regulation 2011 as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, subject to any conditions attached hereto.

**Certificate No.**  
**0843-CPR-1388**

**Issue date**  
30/09/2024

**Issue No.**  
1

**Re-Issue date**  
N/A



470519

**Manufacturer:**

Astroflame Fireseals Ltd

**Address:**

Unit 8, The I.O. Centre

Stephenson Road

Segensworth

Fareham

Hampshire

PO15 5RU

**Product:**

Astro Batt

**Places of production:**

A/008

**Harmonized requirements**

EAD 350454-00-1104, September 2017

**Scope of Certificate**

0843-UKTA-24/0040 issued on 30/09/2024

On behalf of the Head of Approved Body:

A handwritten signature in blue ink, appearing to read 'D. Yates'.

David Yates

Issued by UL International (UK) Ltd, Approved Body 0843.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in UKTA 24/0040 of the above referenced standards, under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate will remain valid as long as neither the EAD, UK Technical Assessments, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the UK Approved body.



**Solutions**

Form-ULID-006104 V8.0

## Detailed information sheet:

Product Reference:	Astro Batt
Type:	Firestop – Penetration Seal
Description:	<p>Astro Batts are a coated mineral wool batt used to reinstate the fire resistance performance of wall constructions where they have been provided with apertures for the penetration of single or multiple services.</p> <p>Product is coated on both faces. The batt is then cut and friction fitted into the aperture in the wall</p>
Key Performance parameters:	See UKTA 24/0040
Accessories:	Astro Intu Mastic, Astro HPE Sealant, Astro PS Coat, Astro X Series CE Pipe Wrap, Astro X Series CE Pipe Collar
Identification and intended use	label on the product. To be used in accordance with the supplier's installation instructions



## Limitations on the acceptance or use of the product(s):

Installation instructions	To be used in accordance with the supplier's installation instructions, technical datasheet and UKTA.
Limitations	See Technical Data Sheet and the UKTA
UL Report:	4791200223

### Terms and Conditions:

1. This certificate remains the property of UL International (UK) Ltd, herein "UL UK", and will be withdrawn if any conditions attached to its issue are not complied with.
2. This certificate is issued subject to the Global Services Agreement (GSA) and UKCA CPR Service Terms.
3. Production is limited to the site(s) as listed, or detailed within the Technical documentation held by UL UK.
4. Any product change, production/process changes, etc. which may affect conformity shall be notified to UL UK.
5. This certificate is only valid for placing goods on the market of United Kingdom excluding Northern Ireland.

END OF CERTIFICATE

